

## **Data Summary Tables for Bournemouth and West Hampshire Water (BWH)**

These tables contain a summary of results of monitoring undertaken by the water company in 2007 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled 'Drinking water 2007'.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

### **Notes relating to the interpretation of the tables : -**

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published June 26<sup>th</sup> 2008  
Drinking Water Inspectorate  
55, Whitehall  
London  
SW1A 2EY

Enquiries : 020 7270 3370

## Data Summary (Q4) for BOURNEMOUTH & WEST HAMPSHIRE WATER PLC

**Table BWH 1: Quality of water leaving service treatment works - European Standards**

Parameter	Parameter Code	Prescribed Concentration or Value	Total number of tests	Tests failed	Minimum	Maximum	No. of works with failures
Nitrite	A013B	0.1 mg NO <sub>2</sub> /l	1406	3	<0.01	<0.01	1
<b>TOTAL</b>	-	-	<b>1406</b>	<b>3</b>	-	-	-

**Table BWH 2: Quality of water leaving service treatment works - National Standards**

Parameter	Parameter Code	Prescribed Concentration or Value	Total number of tests	Tests failed	Minimum	Maximum	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	1401	1	0	0	1
Cryptosporidium	C111	ooocysts >1 in10 litres	1461	0	-	-	0
<i>E. coli</i>	C002	0 number/100 ml	1406	0	0	0	0
<b>TOTAL</b>	-	-	<b>4268</b>	<b>1</b>	-	-	-

**Table BWH 3: Quality of water leaving service treatment works - Additional Monitoring Requirements**

Indicator Parameter	Parameter Code	Prescribed Concentration or Value	Total number of tests	Tests Exceeding Specification	Minimum	Maximum
Colony Counts After 3 Days At 22°C	C007	No abnormal change	1406	N/A	0	60
Colony Counts After 48 Hours At 37°C	C013	No abnormal change	1406	N/A	0	>300
Residual Disinfectant - Free	C009	No abnormal change	1406	N/A	0.01	0.4
Residual Disinfectant - Total	C010	No abnormal change	1406	N/A	0.1207	0.68
Turbidity	A002A	1 NTU	1406	2	<0.1	0.6
<b>TOTAL</b>	-	-	<b>7030</b>	<b>2</b>	-	-

**Table BWH 4: Quality of water leaving service reservoirs - National Standards**

Parameter	Parameter Code	Prescribed Concentration or Value	Total number of tests	Tests failed	Minimum	Maximum	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	1037	0	0	0	0
<i>E. coli</i>	C002	0 number/100 ml	1040	0	0	0	0
<b>TOTAL</b>	-	-	<b>2077</b>	<b>0</b>	-	-	-

**Table BWH 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements**

Indicator Parameter	Parameter Code	Prescribed Concentration or Value	Total number of tests	Tests Exceeding Specification	Minimum	Maximum
Colony Counts After 3 Days At 22°C	C007	No abnormal change	1040	N/A	0	>300
Colony Counts After 48 Hours At 37°C	C013	No abnormal change	1040	N/A	0	>300
Residual Disinfectant - Free	C009	No abnormal change	1040	N/A	0	0.28
Residual Disinfectant - Total	C010	No abnormal change	1040	N/A	0.05	0.5
<b>TOTAL</b>	-	-	<b>4160</b>	<b>0</b>	-	-

**Table BWH 6: Quality of water at consumer's tap (zones) - European Standards**

Parameter	Parameter Code	Prescribed Concentration or Value	Total number of tests	Tests failed	Minimum	Maximum	No. of zones with failures
1,2 Dichloroethane	F001	3 µg/l	81	0	<0.2	<0.2	0
Antimony	B008A	5 µg Sb/l	81	0	<0.05	0.29	0
Arsenic	B001A	10 µg As/l	81	0	<0.3	0.86	0
Benzene	F002	1 µg/l	81	0	<0.1	<0.1	0
Benzo (a) Pyrene	D007	0.01 µg/l	80	0	<0.001	0.0011	0
Boron	D005A	1 mg B/l	81	0	<0.033	0.112	0
Bromate	F003	10 µg BrO <sub>3</sub> /l	108	0	<0.6	9.2	0
Cadmium	B002	5 µg Cd/l	81	0	<0.4	<0.4	0
Chromium	B004	50 µg Cr/l	81	0	<0.5	1.52	0
Copper	A024A	2 mg Cu/l	81	0	0.0026	0.152	0
Cyanide	B003	50 µg CN/l	81	0	<1.6	2.8	0
<i>E. coli</i>	C002	0 number/100 ml	1124	1	0	0	1
Enterococci	C003	0 number/100 ml	83	0	0	0	0
Fluoride	A027	1.5 mg F/l	81	0	0.077	0.281	0
Lead	B007A	25 µg Pb/l	81	0	<0.5	2.87	0
Mercury	B005	1 µg Hg/l	81	0	<0.02	0.058	0
Nickel	B006A	20 µg Ni/l	81	0	<1.5	2.67	0
Nitrate	A012	50 mg NO <sub>3</sub> /l	430	0	3.5979	37.79	0
Nitrite	A013A	0.5 mg NO <sub>2</sub> /l	430	1	<0.01	0.4269	1
Nitrate/Nitrite Formula	A013C	1 mg NO <sub>2</sub> /l	430	0	0.1693	0.76	0
Polycyclic aromatic hydrocarbons (PAHs)	B011F	0.1 µg/l	80	0	0	0.009	0
Selenium	B009	10 µg Se/l	81	0	<0.4	1.4	0
Tetrachloroethene/Trichloroethene	D009B	10 µg/l	81	0	0	0	0
Trihalomethanes (THMs)	D011	100 µg/l	81	0	0.2	57.7	0
Pesticides (2,4,-Db)	P082	0.1 µg/l	78	0	<0.003	<0.003	0
Pesticides (2,4-D)	P020	0.1 µg/l	78	0	<0.004	<0.004	0
Pesticides (Atrazine)	P004	0.1 µg/l	80	0	<0.004	0.005	0
Pesticides (Azoxystrobin)	P227	0.1 µg/l	80	0	<0.004	<0.004	0
Pesticides (Benazolin)	P138	0.1 µg/l	78	0	<0.004	<0.004	0
Pesticides (Bentazone)	P006	0.1 µg/l	78	0	<0.003	<0.003	0
Pesticides (Bromoxynil)	P008	0.1 µg/l	78	0	<0.003	<0.003	0
Pesticides (Carbendazim)	P150	0.1 µg/l	80	0	<0.004	<0.004	0
Pesticides (Chlorfenvinphos)	P013	0.1 µg/l	81	0	<0.009	<0.009	0
Pesticides (Chlorothalonil)	P015	0.1 µg/l	81	0	<0.004	<0.004	0
Pesticides (Chlorpropham)	P016	0.1 µg/l	80	0	<0.002	<0.002	0
Pesticides (Chlorpyrifos)	P017	0.1 µg/l	81	0	<0.004	<0.004	0
Pesticides (Chlortoluron)	P014	0.1 µg/l	80	0	<0.004	<0.004	0

Parameter	Parameter Code	Prescribed Concentration or Value	Total number of tests	Tests failed	Minimum	Maximum	No. of zones with failures
Pesticides (Clopyralid)	P018	0.1 µg/l	78	0	<0.006	<0.006	0
Pesticides (Cypermethrin)	P094	0.1 µg/l	81	0	<0.014	<0.014	0
Pesticides (Cyprodinil)	P228	0.1 µg/l	81	0	<0.003	<0.003	0
Pesticides (Diazinon)	P024	0.1 µg/l	81	0	<0.004	<0.004	0
Pesticides (Dicamba)	P025	0.1 µg/l	78	0	<0.002	<0.002	0
Pesticides (Dichlobenil)	P098	0.1 µg/l	81	0	<0.002	<0.002	0
Pesticides (Dichlorprop)	P026	0.1 µg/l	78	0	<0.004	<0.004	0
Pesticides (Dieldrin)	P028	0.03 µg/l	81	0	<0.007	<0.007	0
Pesticides (Diflufenican)	P157	0.1 µg/l	81	0	<0.003	<0.003	0
Pesticides (Diuron)	P032	0.1 µg/l	80	0	<0.004	<0.004	0
Pesticides (Epoxyconazole)	P217	0.1 µg/l	81	0	<0.009	<0.009	0
Pesticides (Fenpropimorph)	P037	0.1 µg/l	81	0	<0.006	<0.006	0
Pesticides (Flusilazole)	P159	0.1 µg/l	80	0	<0.009	<0.009	0
Pesticides (Gamma-HCH (Lindane))	P041	0.1 µg/l	81	0	<0.004	<0.004	0
Pesticides (Heptachlor)	P043	0.03 µg/l	81	0	<0.008	<0.008	0
Pesticides (Heptachlor epoxide)	P044	0.03 µg/l	81	0	<0.003	<0.003	0
Pesticides (Ioxynil)	P049	0.1 µg/l	78	0	<0.007	<0.007	0
Pesticides (Isoproturon)	P048	0.1 µg/l	80	0	<0.004	<0.004	0
Pesticides (Kresoxym-Methyl)	P218	0.1 µg/l	81	0	<0.003	<0.003	0
Pesticides (Linuron)	P051	0.1 µg/l	80	0	<0.005	<0.005	0
Pesticides (MCPA)	P054	0.1 µg/l	78	0	<0.004	<0.004	0
Pesticides (MCPB)	P055	0.1 µg/l	78	0	<0.003	<0.003	0
Pesticides (MCPP(Mecoprop))	P053	0.1 µg/l	78	0	<0.002	<0.002	0
Pesticides (Pendimethalin)	P118	0.1 µg/l	81	0	<0.003	<0.003	0
Pesticides (Pentachlorophenol)	P060	0.1 µg/l	78	0	<0.003	<0.003	0
Pesticides (Permethrin)	P119	0.1 µg/l	81	0	<0.008	<0.008	0
Pesticides (Picloram)	P122	0.1 µg/l	78	0	<0.007	<0.007	0
Pesticides (Propetamphos)	P069	0.1 µg/l	81	0	<0.004	<0.004	0
Pesticides (Propyzamide)	P071	0.1 µg/l	80	0	<0.003	<0.003	0
Pesticides (Simazine)	P073	0.1 µg/l	80	0	<0.004	<0.004	0
Pesticides (Sulcofuron)	P171	0.1 µg/l	80	0	<0.014	<0.014	0
Pesticides (Tebuconazole)	P177	0.1 µg/l	81	0	<0.005	<0.005	0
Pesticides (Tri-allate)	P079	0.1 µg/l	81	0	<0.003	<0.003	0
Pesticides (Trichlopyr)	P131	0.1 µg/l	78	0	<0.002	<0.002	0
Pesticides (Trifloxystrobin)	P229	0.1 µg/l	80	0	<0.004	<0.004	0
Pesticides (Trifluralin)	P081	0.1 µg/l	81	0	<0.005	<0.005	0
Pesticides - Total Substances	B010	0.5 µg/l	94	0	0	0.005	0
<b>TOTAL</b>	-	-	<b>8066</b>	<b>2</b>	-	-	-

**Table BWH 7: Quality of water at consumer's tap (zones) - National Standards**

Parameter	Parameter Code	Prescribed Concentration or Value	Total number of tests	Tests failed	Minimum	Maximum	No. of zones with failures
Aluminium	A021	200 µg Al/l	341	0	<2	69.35	0
Colour	A001	20 mg/l Pt/Co scale	430	0	0.4	4.907	0
Hydrogen ion (pH)	A006	6.5 -10 pH value	430	0	7.331	8.269	0
Iron	A022	200 µg Fe/l	341	1	<9	111.97	1
Manganese	A023	50 µg Mn/l	341	0	<2	6.9708	0
Organoleptic Odour	A003	Dilution no. 3 at 25°C	429	0	0	0	0
Organoleptic Taste	A004	Dilution no. 3 at 25°C	427	1	0	0	1
Sodium	A009	200 mg Na/l	81	0	7.9	18	0
Tetrachloromethane	D008	3 µg/l	81	0	<0.1	<0.1	0
Turbidity	A002	4 NTUs	430	0	<0.1	0.938	0
<b>TOTAL</b>	-	-	<b>3331</b>	<b>2</b>	-	-	-

**Table BWH 8: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements**

Indicator Parameter	Parameter Code	Prescribed Concentration or Value	Total number of tests	Tests Exceeding Specification	Minimum	Maximum
Ammonium	A014	0.5 mg NH <sub>4</sub> /l	430	0	<0.01	0.21
Chloride	D002A	250 mg Cl/l	81	0	18	32
<i>Clostridium perfringens</i>	C004A	0 number/100 ml	336	0	0	0
Coliform Bacteria	C001A	0 number/100 ml	1124	2	0	0
Colony Counts After 3 Days At 22°C	C007	No abnormal change	432	N/A	0	>300
Colony Counts After 48 Hours At 37°C	C013	No abnormal change	432	N/A	0	>300
Conductivity	D001	2500 µS/cm	430	0	402.1	537
Hydrogen ion (pH)	A006A	9.5 pH Value	430	0	7.331	8.269
Radioactivity - Gross Alpha	F004	0.1 Bq/l	81	0	<0.02	0.073
Radioactivity - Gross Beta	F005	1 Bq/l	81	0	<0.06	0.224
Radioactivity - Total Indicative Dose	F007	0.1 mSv/year	81	0	<0.1	<0.1
Radioactivity - Tritium	F006	100 Bq/l	81	0	<10	<10
Residual Disinfectant - Free	C009	No abnormal change	1125	N/A	0.01	0.23
Residual Disinfectant - Total	C010	No abnormal change	1124	N/A	0.06	0.55
Sulphate	A007	250 mg SO <sub>4</sub> /l	81	0	11	69.6
Total Organic Carbon (TOC)	A017	No abnormal change	81	N/A	0.6	5.1
<b>TOTAL</b>	-	-	<b>6430</b>	<b>2</b>	-	-