

## **Data Summary Tables for Dee Valley Water (DVW)**

These tables contain a summary of results of monitoring undertaken by the water company in 2008 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled 'Drinking water 2008'.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

### **Notes relating to the interpretation of the tables : -**

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published July 2<sup>nd</sup> 2009  
Drinking Water Inspectorate  
55, Whitehall  
London  
SW1A 2EY

Enquiries : 020 7270 3370

## Site Summary Data for Dee Valley Water Plc

Report Date Range: For the whole year 2008

**Table DVW 1: Quality of water leaving treatment works - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Works)	A013B	0.1 mg NO <sub>2</sub> /l	406	1	0.003	0.022	1
<b>Totals:</b>			<b>406</b>	<b>1</b>			

**Table DVW 2: Quality of water leaving treatment works - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	1,201	3	0	0	3
Cryptosporidium	C111	(see note*)	1,109	0			0
E Coli	C002	0 number/100 ml	1,201	0	0	0	0
<b>Totals:</b>			<b>3,511</b>	<b>3</b>			

**Table DVW 3: Quality of water leaving treatment works - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	1,202	N/A	0	231.11
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	1,202	N/A	0	7.97
Residual Disinfectant - Free	C009	No abnormal change	1,203	N/A	< 0.02	0.6
Residual Disinfectant - Total	C010	No abnormal change	1,203	N/A	0.02	0.75
Turbidity (Indicator)	A002A	1 nephelometric turbidity unit	1,201	9	< 0.04	0.959
<b>Totals:</b>			<b>6,011</b>	<b>9</b>		

\* Note : The Standard for *Cryptosporidium* ceased to exist when regulations changed from 22nd December 2007 but the regulatory monitoring related to *Cryptosporidium* risk assessments continued until 1st October.

**Table DVW 4: Quality of water leaving service reservoirs - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	1,624	4	0	0	0
E Coli	C002	0 number/100 ml	1,624	0	0	0	0
<b>Totals:</b>			<b>3,248</b>	<b>4</b>			

**Table DVW 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	1,627	N/A	0	60.32
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	1,627	N/A	0	4
Residual Disinfectant - Free	C009	No abnormal change	1,627	N/A	< 0.02	0.7
Residual Disinfectant - Total	C010	No abnormal change	1,627	N/A	0.02	0.8
<b>Totals:</b>			<b>6,508</b>	<b>0</b>		

Table DVW 6: Quality of water leaving bulk supply points - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
1,2 Dichloroethane	F001	3 µg/l	48	0	< 0.08	< 0.08	0
Benzene	F002	1 µg/l	48	0	< 0.04	0.1	0
Boron	D005A	1 mg B/l	48	0	< 0.003	0.033	0
Bromate	F003	10 µg BrO <sub>3</sub> /l	48	0	< 0.5	0.7	0
Cyanide	B003	50 µg CN/l	48	0	< 0.6	1.8	0
Fluoride	A027	1.5 mg F/l	48	0	< 0.03	0.27	0
Mercury	B005	1 µg Hg/l	48	0	< 0.1	0.1	0
Pesticides - Total Substances	B010	0.5 µg/l	50	0	0	0.03	0
Pesticides 2,4,-Db	P082	0.1 µg/l	48	0	< 0.01	< 0.014	0
Pesticides 2,4-D	P020	0.1 µg/l	48	0	< 0.009	< 0.01	0
Pesticides Aldrin	P002	0.03 µg/l	48	0	< 0.002	< 0.003	0
Pesticides Atrazine	P004	0.1 µg/l	50	0	< 0.01	< 0.01	0
Pesticides Bromoxynil	P008	0.1 µg/l	48	0	< 0.006	< 0.01	0
Pesticides Carbendazim	P150	0.1 µg/l	48	0	< 0.003	< 0.01	0
Pesticides Chloromequat	P163	0.1 µg/l	50	0	< 0.004	< 0.01	0
Pesticides Clopyralid	P018	0.1 µg/l	49	0	< 0.01	0.02	0
Pesticides Diazinon	P024	0.1 µg/l	49	0	< 0.01	< 0.01	0
Pesticides Dieldrin	P028	0.03 µg/l	49	0	< 0.002	< 0.003	0
Pesticides Diuron	P032	0.1 µg/l	48	0	< 0.003	< 0.01	0
Pesticides Fluroxypyr	P040	0.1 µg/l	49	0	< 0.002	< 0.01	0
Pesticides Heptachlor	P043	0.03 µg/l	50	0	< 0.001	< 0.002	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	49	0	< 0.002	< 0.003	0
Pesticides Isoproturon	P048	0.1 µg/l	48	0	< 0.003	< 0.01	0
Pesticides Linuron	P051	0.1 µg/l	48	0	< 0.002	< 0.01	0
Pesticides MCPA	P054	0.1 µg/l	48	0	< 0.007	0.02	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	48	0	< 0.01	0.01	0
Pesticides Propetamphos	P069	0.1 µg/l	54	0	< 0.01	< 0.01	0
Pesticides Simazine	P073	0.1 µg/l	49	0	< 0.003	< 0.01	0
Pesticides Trichlopyr	P131	0.1 µg/l	48	0	< 0.01	< 0.016	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	48	0	0	0.09	0
<b>Totals:</b>			<b>1,460</b>	<b>0</b>			

**Table DVW 7: Quality of water leaving bulk supply points - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Tetrachloromethane	D008	3 µg/l	48	0	< 0.02	< 0.05	0
<b>Totals:</b>			<b>48</b>	<b>0</b>			

**Table DVW 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Chloride (Indicator)	D002A	250 mg Cl/l	48	0	9.2	61.2
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	309	0	0	0
Conductivity (Indicator)	D001	2500 µS/cm	308	0	78.09	630
Gross Alpha Activity	F004	0.1 Bq/l	48	0	< 0.012	0.036
Gross Beta Activity	F005	1 Bq/l	48	0	0.037	0.252
Sulphate (Indicator)	A007	250 mg SO <sub>4</sub> /l	48	0	14	59
Total organic carbon (indicator)	A017	No abnormal change	48	N/A	0.2	2.5
<b>Totals:</b>			<b>857</b>	<b>0</b>		

Table DVW 9: Quality of water at consumer's tap (zones) - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
1,2 Dichloroethane	F001	3 µg/l	4	0	< 0.08	< 0.08	0
Antimony	B008A	5 µg Sb/l	132	0	0	0.3	0
Arsenic	B001A	10 µg As/l	132	0	0.1	7.3	0
Benzene	F002	1 µg/l	4	0	< 0.04	< 0.04	0
Benzo (a) Pyrene	D007	0.01 µg/l	134	0	< 0.001	0.005	0
Boron	D005A	1 mg B/l	4	0	< 0.003	0.009	0
Bromate	F003	10 µg BrO <sub>3</sub> /l	77	0	< 0.5	0.7	0
Cadmium	B002	5 µg Cd/l	132	0	< 0.02	0.381	0
Chromium	B004	50 µg Cr/l	132	0	< 0.2	2	0
Copper	A024A	2 mg Cu/l	132	0	0.001	0.547	0
Cyanide	B003	50 µg CN/l	4	0	< 0.6	< 0.7	0
E Coli	C002	0 number/100 ml	768	0	0	0	0
Enterococci	C003	0 number/100 ml	132	0	0	0	0
Fluoride	A027	1.5 mg F/l	4	0	< 0.03	0.07	0
Lead	B007A	25 µg Pb/l	132	2	0.1	38.384	1
Mercury	B005	1 µg Hg/l	4	0	< 0.1	< 0.1	0
Nickel	B006A	20 µg Ni/l	132	0	< 0.3	14.235	0
Nitrate	A012	50 mg NO <sub>3</sub> /l	208	0	0.513	15.087	0
Nitrate/Nitrite Formula	A013C	1 mg NO <sub>2</sub> /l	208	0	0.011	0.394	0
Nitrite (Consumers tap)	A013A	0.5 mg NO <sub>2</sub> /l	208	3	0.003	0.573	3
Pesticides - Total Substances	B010	0.5 µg/l	4	0	0	0	0
Pesticides 2,4,-Db	P082	0.1 µg/l	5	0	< 0.01	< 0.014	0
Pesticides 2,4-D	P020	0.1 µg/l	5	0	< 0.01	< 0.01	0
Pesticides Aldrin	P002	0.03 µg/l	4	0	< 0.002	< 0.002	0
Pesticides Atrazine	P004	0.1 µg/l	4	0	< 0.01	< 0.01	0
Pesticides Bromoxynil	P008	0.1 µg/l	5	0	< 0.01	< 0.01	0
Pesticides Carbendazim	P150	0.1 µg/l	4	0	< 0.003	< 0.01	0
Pesticides Chloromequat	P163	0.1 µg/l	4	0	< 0.01	< 0.01	0
Pesticides Clopyralid	P018	0.1 µg/l	4	0	< 0.01	< 0.01	0
Pesticides Diazinon	P024	0.1 µg/l	5	0	< 0.01	< 0.01	0
Pesticides Dieldrin	P028	0.03 µg/l	4	0	< 0.003	< 0.003	0
Pesticides Diuron	P032	0.1 µg/l	4	0	< 0.003	< 0.01	0
Pesticides Fluroxypyr	P040	0.1 µg/l	4	0	< 0.01	< 0.01	0
Pesticides Heptachlor	P043	0.03 µg/l	5	0	< 0.001	< 0.001	0

Pesticides Heptachlor epoxide	P044	0.03 µg/l	4	0	< 0.003	< 0.003	0
Pesticides Isoproturon	P048	0.1 µg/l	4	0	< 0.003	< 0.01	0
Pesticides Linuron	P051	0.1 µg/l	4	0	< 0.002	< 0.01	0
Pesticides MCPA	P054	0.1 µg/l	4	0	< 0.01	< 0.01	0
Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	4	0	< 0.01	< 0.01	0
Pesticides Propetamphos	P069	0.1 µg/l	5	0	< 0.01	< 0.01	0
Pesticides Simazine	P073	0.1 µg/l	4	0	< 0.003	< 0.01	0
Pesticides Trichlopyr	P131	0.1 µg/l	4	0	< 0.01	< 0.016	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	137	0	0	0.016	0
Selenium	B009	10 µg Se/l	132	0	0.2	1	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	4	0	0	0.04	0
Total Trihalomethanes	D011	100 µg/l	134	0	0.063	65.49	0
<b>Totals:</b>			<b>3,184</b>	<b>5</b>			

**Table DVW 10: Quality of water at consumer's tap (zones) - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
Aluminium	A021	200 µg Al/l	324	0	< 2.6	100.625	0
Colour	A001	20 mg/l Pt/Co scale	324	0	0.3	3.725	0
Iron	A022	200 µg Fe/l	324	2	< 2	188.25	2
Manganese	A023	50 µg Mn/l	324	2	0	31.75	1
Organoleptic Odour	A003	<1 dilution number at 25°C	324	0			0
Organoleptic Taste	A004	<1 dilution number at 25°C	324	0			0
Sodium	A009	200 mg Na/l	132	0	4.4	32.367	0
Tetrachloromethane	D008	3 µg/l	4	0	< 0.02	0.04	0
Turbidity	A002	4 nephelometric turbidity units	324	0	< 0.04	1.22	0
<b>Totals:</b>			<b>2,404</b>	<b>4</b>			

**Table DVW 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH <sub>4</sub> /l	324	0	< 0.018	0.27
Chloride (Indicator)	D002A	250 mg Cl/l	4	0	11.9	14.2
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	4	0	0	0
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	768	1	0	0
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	324	N/A	0	19.5
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	324	N/A	0	15.25
Conductivity (Indicator)	D001	2500 µS/cm	4	0	130	139
Gross Alpha Activity	F004	0.1 Bq/l	4	0	< 0.012	0.02
Gross Beta Activity	F005	1 Bq/l	4	0	0.046	0.135
Hydrogen ion (pH)	A006	6.5 - 9.5 pH range	324	1	6.63	7.968
Residual Disinfectant - Free	C009	No abnormal change	768	N/A	< 0.02	0.55
Residual Disinfectant - Total	C010	No abnormal change	768	N/A	< 0.02	0.65
Sulphate (Indicator)	A007	250 mg SO <sub>4</sub> /l	4	0	36	40
Total organic carbon (indicator)	A017	No abnormal change	4	N/A	1.8	2.4
<b>Totals:</b>			<b>3,628</b>	<b>2</b>		