

## **Data Summary Tables for Sutton and East Surrey Water (SES)**

These tables contain a summary of results of monitoring undertaken by the water company in 2008 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled 'Drinking water 2008'.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.gov.uk>

### **Notes relating to the interpretation of the tables : -**

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published July 2<sup>nd</sup> 2009  
Drinking Water Inspectorate  
55, Whitehall  
London  
SW1A 2EY

Enquiries : 020 7270 3370

## Site Summary Data for Sutton And East Surrey Water Plc

Report Date Range: For the whole year 2008

**Table SES 1: Quality of water leaving treatment works - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Works)	A013B	0.1 mg NO <sub>2</sub> /l	2,168	0	< 0.01	0.01	0
<b>Totals:</b>			<b>2,168</b>	<b>0</b>			

**Table SES 2: Quality of water leaving treatment works - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Coliform Bacteria	C001	0 number/100 ml	2,168	1	0	0	1
Cryptosporidium	C111	(see note*)	366	0			0
E Coli	C002	0 number/100 ml	2,168	1	0	0	1
<b>Totals:</b>			<b>4,702</b>	<b>2</b>			

**Table SES 3: Quality of water leaving treatment works - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	2,168	N/A	0	4
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	2,168	N/A	0	3
Residual Disinfectant - Total	C010	No abnormal change	2,168	N/A	0.19	1.29
Turbidity (Indicator)	A002A	1 nephelometric turbidity unit	2,168	0	< 0.07	0.24
<b>Totals:</b>			<b>8,672</b>	<b>0</b>		

\* Note : The Standard for *Cryptosporidium* ceased to exist when regulations changed from 22nd December 2007 but the regulatory monitoring related to *Cryptosporidium* risk assessments continued until 1st October.

**Table SES 4: Quality of water leaving service reservoirs - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
Coliform Bacteria	C001	0 number/100 ml	1,696	0	0	0	0
E Coli	C002	0 number/100 ml	1,696	0	0	0	0
<b>Totals:</b>			<b>3,392</b>	<b>0</b>			

**Table SES 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	1,696	N/A	0	> 2000
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	1,696	N/A	0	11
Residual Disinfectant - Total	C010	No abnormal change	1,696	N/A	< 0.04	0.96
<b>Totals:</b>			<b>5,088</b>	<b>0</b>		

**Table SES 6: Quality of water leaving bulk supply points - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Boron	D005A	1 mg B/l	61	0	< 0.005	0.078	0
Bromate	F003	10 µg BrO <sub>3</sub> /l	61	0	< 0.5	1.6	0
Cyanide	B003	50 µg CN/l	61	0	< 0.7	3.8	0
Fluoride	A027	1.5 mg F/l	61	0	< 0.06	0.19	0
Mercury	B005	1 µg Hg/l	61	0	< 0.04	0.24	0
Pesticides - Total Substances	B010	0.5 µg/l	61	2	0	0.549	1
Pesticides 2,4,-Db	P082	0.1 µg/l	61	0	< 0.002	< 0.005	0
Pesticides 2,4-D	P020	0.1 µg/l	61	0	< 0.004	0.006	0
Pesticides Aldrin	P002	0.03 µg/l	61	0	< 0.002	< 0.002	0
Pesticides Atrazine	P004	0.1 µg/l	61	0	< 0.012	0.063	0
Pesticides Azoxystrobin	P227	0.1 µg/l	61	0	< 0.003	0.037	0
Pesticides Bromoxynil	P008	0.1 µg/l	8	0	< 0.002	< 0.005	0
Pesticides Carbenazim	P150	0.1 µg/l	8	0	< 0.01	< 0.01	0
Pesticides Carbetamide	P010	0.1 µg/l	61	0	< 0.009	< 0.009	0
Pesticides Chloromequat	P163	0.1 µg/l	8	0	< 0.004	< 0.004	0
Pesticides Chlorothalonil	P015	0.1 µg/l	61	0	< 0.002	< 0.002	0
Pesticides Chlortoluron	P014	0.1 µg/l	61	0	< 0.006	0.027	0
Pesticides Dieldrin	P028	0.03 µg/l	61	0	< 0.003	0.003	0
Pesticides Diuron	P032	0.1 µg/l	61	0	< 0.003	< 0.003	0
Pesticides Fenpropimorph	P037	0.1 µg/l	61	0	< 0.005	0.006	0
Pesticides Flusilazole	P159	0.1 µg/l	61	0	< 0.009	< 0.009	0
Pesticides Flutriafol	P039	0.1 µg/l	61	0	< 0.009	0.019	0
Pesticides Glyphosate	P042	0.1 µg/l	61	1	< 0.012	0.168	1
Pesticides Heptachlor	P043	0.03 µg/l	61	0	< 0.002	< 0.002	0
Pesticides Heptachlor epoxide	P044	0.03 µg/l	61	0	< 0.003	< 0.003	0
Pesticides Isoproturon	P048	0.1 µg/l	61	0	< 0.006	< 0.006	0

Pesticides MCPP(Mecoprop)	P053	0.1 µg/l	61	0	< 0.002	0.05	0
Pesticides Metaldehyde	P226	0.1 µg/l	8	7	0.053	0.433	1
Pesticides Metazachlor	P203	0.1 µg/l	8	0	< 0.003	0.005	0
Pesticides Methabenzthiazuron	P167	0.1 µg/l	61	0	< 0.003	< 0.003	0
Pesticides Pendimethalin	P118	0.1 µg/l	61	0	< 0.008	< 0.008	0
Pesticides Propachlor	P126	0.1 µg/l	8	0	< 0.005	0.005	0
Pesticides Propyzamide	P071	0.1 µg/l	61	0	< 0.009	0.017	0
Pesticides Simazine	P073	0.1 µg/l	61	0	< 0.003	0.062	0
Pesticides Tebuconazole	P177	0.1 µg/l	61	0	< 0.009	< 0.009	0
Pesticides Trichlopyr	P131	0.1 µg/l	61	0	< 0.005	0.023	0
Pesticides Trifluralin	P081	0.1 µg/l	61	0	< 0.002	< 0.002	0
<b>Totals:</b>			<b>1,939</b>	<b>10</b>			

**Table SES 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Chloride (Indicator)	D002A	250 mg Cl/l	61	0	15.9	45.3
Clostridium Perfringens (Indicator)	C004A	0 number/100 ml	308	0	0	0
Conductivity (Indicator)	D001	2500 µS/cm	710	0	305	565.89
Gross Alpha Activity	F004	0.1 Bq/l	8	0	< 0.027	0.043
Gross Beta Activity	F005	1 Bq/l	8	0	0.091	0.161
Sulphate (Indicator)	A007	250 mg SO <sub>4</sub> /l	61	0	13.3	98.1
Total organic carbon (indicator)	A017	No abnormal change	61	N/A	< 0.3	4.51
<b>Totals:</b>			<b>1,217</b>	<b>0</b>		

**Table SES 9: Quality of water at consumer's tap (zones) - European Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
1,2 Dichloroethane	F001	3 µg/l	160	0	< 0.17	< 0.17	0
Antimony	B008A	5 µg Sb/l	160	0	< 0.02	0.604	0
Arsenic	B001A	10 µg As/l	160	0	< 0.04	0.9	0
Benzene	F002	1 µg/l	160	0	< 0.02	< 0.02	0
Benzo (a) Pyrene	D007	0.01 µg/l	157	0	< 0.001	< 0.001	0
Cadmium	B002	5 µg Cd/l	160	0	< 0.01	0.131	0
Chromium	B004	50 µg Cr/l	160	0	< 0.1	1.251	0
Copper	A024A	2 mg Cu/l	160	0	0.002	0.216	0
E Coli	C002	0 number/100 ml	1,657	0	0	0	0
Enterococci	C003	0 number/100 ml	160	0	0	0	0
Lead	B007A	25 µg Pb/l	160	0	< 0.2	8.217	0
Nickel	B006A	20 µg Ni/l	160	0	< 0.7	4.951	0
Nitrate	A012	50 mg NO <sub>3</sub> /l	645	0	6.346	40.254	0
Nitrate/Nitrite Formula	A013C	1 mg NO <sub>2</sub> /l	645	0	0.2	0.8	0
Nitrite (Consumers tap)	A013A	0.5 mg NO <sub>2</sub> /l	645	0	< 0.01	0.306	0
Polycyclic aromatic hydrocarbons	B011F	0.1 µg/l	157	0	0	0.003	0
Selenium	B009	10 µg Se/l	160	0	< 0.3	1.57	0
Tetrachloroethene/Trichloroethene - sum of two substances	D009B	10 µg/l	160	0	0	2.239	0
Total Trihalomethanes	D011	100 µg/l	160	0	1	67.39	0
<b>Totals:</b>			<b>5,986</b>	<b>0</b>			

**Table SES 10: Quality of water at consumer's tap (zones) - National Standards**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones with failures
Aluminium	A021	200 µg Al/l	381	0	< 4	52.52	0
Colour	A001	20 mg/l Pt/Co scale	645	0	< 0.6	4.854	0
Iron	A022	200 µg Fe/l	513	1	< 1	100.72	1
Manganese	A023	50 µg Mn/l	381	0	< 0.5	4.236	0
Organoleptic Odour	A003	<1 dilution number at 25°C	645	2			2
Organoleptic Taste	A004	<1 dilution number at 25°C	645	0			0
Sodium	A009	200 mg Na/l	160	0	10.783	27.636	0
Tetrachloromethane	D008	3 µg/l	160	0	< 0.08	< 0.08	0
Turbidity	A002	4 nephelometric turbidity units	645	0	< 0.07	0.371	0
<b>Totals:</b>			<b>4,175</b>	<b>3</b>			

**Table SES 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements**

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Indicator)	A014	0.5 mg NH <sub>4</sub> /l	645	0	< 0.01	0.225
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	1,657	0	0	0
Colony Counts After 3 Days At 22°C (Indicator)	C007	No abnormal change	645	N/A	0	78.48
Colony Counts After 48 Hours At 37°C (Indicator)	C013	No abnormal change	645	0	0	44.62
Hydrogen ion (pH)	A006	6.5 - 9.5 pH range	645	0	7.3	8
Residual Disinfectant - Total	C010	No abnormal change	1,657	N/A	< 0.04	0.934
<b>Totals:</b>			<b>5,894</b>	<b>0</b>		